

## **ADDENDUM #1**

### **Fairgrounds Roofing Project**

**Project Specifications #6** – Roofing system shall include necessary flashing and unvented ridge cap. Flashing and ridge cap shall be from the same supplier as metal roof panels and be of the same finish.

Flashing noted in specification #6 does include eve and gable “trim” flashing as necessary to protect the roofing system from moisture.